

4(1)

Fire Cools



☎: 0821-2480671 Fax: 0821-2486104
E-mail: firecoolmysore@gmail.com
firecoolmysore@yahoo.com

125/1, 2nd Main, 10th Cross, Vidyananyapuram, Mysore-570008

Ref :- FC/GEN/2021-2022

Date: 26-07-2021

Fire Safety Extinguishers Installed in the School

This is to certify that the Fire Cools have installed 14 nos of Fire Extinguisher in Sambhota Tibetan School Cauvery Valley Project School Bylakuppe on 28/01/2019 as per the list given below in different blocks to provide Fire Safety measures as per the request from the School Office. At the same time after installation we have given demonstration and drilling exercise for the working and use of Fire Extinguisher to the staff and the students. The school Zone is well equipped with Fire Extinguisher in different blocks of the school for Fire Safety.

S.no	Name of the Block	Type of Particulars	Nos of Fire Extinguisher installed	Expiry Date
1	Block A Office Section	ABC 6 Kg Capacity CO ₂ 2 Kg Capacity	2 nos 1 no	26-07-2021 to 25-07-2022
2	Block A Lab section, Up stair	ABC 6 Kg Capacity CO ₂ 2 Kg Capacity	1 no 1 no	26-07-2021 to 25-07-2022
3	Block B Primary Section Up stair	ABC 6 Kg Capacity	1 no	26-07-2021 to 25-07-2022
4	Block B Primary Section Ground	ABC 6 Kg Capacity	1 no	26-07-2021 to 25-07-2022
5	Block C Up Stair English and Music Dance Room	ABC 6 Kg Capacity	1 no	26-07-2021 to 25-07-2022
6	Block C Ground Social lab and Counseling Room	ABC 6 Kg Capacity	1 no	26-07-2021 to 25-07-2022
7	Block D School Kitchen	CO ₂ 2 Kg Capacity	1 no	26-07-2021 to 25-07-2022
8	Block E School Community Hall	CO ₂ 2 Kg Capacity	2 nos	26-07-2021 to 25-07-2022
9	School Generator Room	ABC 6 Kg Capacity	1 no	26-07-2021 to 25-07-2022
10	Primary Students Library	ABC 6 Kg Capacity	1 no	26-07-2021 to 25-07-2022

Attested by
[Signature]
Principal
Sambhota Tibetan School
CVP Bylakuppe

Attested by
[Signature]
Director
Sambhota Tibetan Schools Society
Khangyara, Dharammala-572118

[Signature]
Seal and Signature